

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From:
The Director General,
State Disaster Response & Fire Services
Andhra Pradesh, Vijayawada.

To:
The Management,
M/s Don Bosco School (The Guntupalli
Don Bosco Society), located at
R.S.No.243 & 244, D.No.5-132/2,
Guntupalli Village, NTR District.

Rc.No.5298/Non-HRB/ER/KRI/2021, Dt. 01-01-2023

Sir,

Sub:- A.P. State Disaster Response and Fire Services Department-MSB
Section- NTR District- change the Name from **Don Bosco Primary
School (The Guntupalli Don Bosco Society) to Don Bosco School (The
Guntupalli Don Bosco Society)**, located at R.S.No.243 & 244, D.No.5-
132/2, Guntupalli Village, NTR District -Regarding.

Ref:- 1) This Office NOC for Occupancy issued vide Rc.No.5298/Non-
HRB/ER/KRI/2021, Dated: 28-10-2021.
2) Name Change proposal of M/s Don Bosco School (The Guntupalli
Don Bosco Society), located at R.S.No.243 & 244, D.No.5-132/2,
Guntupalli Village, NTR District.

<< 0 >>

The Management has Obtained NOC for Occupancy from this Department vide ref
1st cited to the existing building on the name of Don Bosco Primary School (The Guntupalli
Don Bosco Society) located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Village, NTR
District with Ground + (02) upper floors with a height of 11.40 Mtrs., for Educational
Occupancy.

2) The Management of M/s Don Bosco School (The Guntupalli Don Bosco Society),
located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Village, NTR District has requested
that they have change their School name from **Don Bosco Primary School (The
Guntupalli Donbosco Society) to Don Bosco School (The Guntupalli Don Bosco
Society)**, they requested to change the name of their Building in Fire No Objection
Certificate. The Management has remitted the Fire Precautionary Fee of Rs.3500/- vide
Challan No.61322044472022 Dated.20-12-2022 and towards the change of name, into
Government account through online payment as per G.O.Ms.No.71 Home (Prisons-A)
Dept., Dt.01-04-2010.

3) Under the above circumstances, the change of name from **Don Bosco Primary
School (The Guntupalli Don Bosco Society) to Don Bosco School (The Guntupalli Don
Bosco Society)**, of the said premises is here by modified.



Director General
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to :

- (i). The Regional Fire Officer, Eastern Region, Vijayawada.
- (ii). The DDR & FO, NTR District.

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The District Educational Officer,
Krishna District.

Rc.No. 5298/Non-HRB/ER/KRI/2021, Dt: 28.10.2021

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-Issuance of No Objection Certificate for Occupancy to Educational Building of M/s Donbosco Primary School (The Guntupalli Donbosco Society), located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Grama Panchayat, Ibrahimpatnam Mandal, Krishna District -Regarding.

- Ref:-
1. Application of Educational Building of M/s Donbosco Primary School (The Guntupalli Donbosco Society), located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Grama Panchayat, Ibrahimpatnam Mandal, Krishna District.
 2. Self certification of the Management.

* * * * *

The Management of M/s Donbosco Primary School (The Guntupalli Donbosco Society), located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Grama Panchayat, Ibrahimpatnam Mandal, Krishna District has requested to issue No Objection Certificate for Occupancy vide reference 1stcited.

2) The Management has submitted the self certification for Educational Building with a height of 11.40 Mtrs with Ground + (02) Upper floors without kitchen and without A/c and stated that, they have provided the following Fire Safety Measures:

Sl.No.	Name of the equipment	:	Fire Safety Measures	Available with Nos.
1.	Staircases	:	*Minimum (02) shall be ProvidedorAdjacent buildings can be connected through rail fenced pathway to get access to staircase.	06 Nos.
2.	Fire fighting equipment	:	1) *Extinguishers (01 Extinguisher of ABC type for each class room)	34 Nos.
		:	2) Whether Hose Reel provided or not?	12 Nos.
		:	3) *Manually operated electronic fire alarm system	NO
		:	4) *Terrace Tank 10,000 Ltrs.,	20,000 Ltrs.,
		:	5) *2 HP Motor with triplex Pump Shall be connected to normal plumbing system at ground floor and also at alternate upper floors.	02 Nos.
		:	6) *Display the following Nos. at Kitchen & other important areas (i) Fire Department number. (ii) Ambulance (iii) Police	Yes
3.	Kindergarten class rooms	:	*Shall be located on ground floor preferably.	Yes
4.	Class-I to IV	:	*Shall be located either on ground or on first floor preferably.	Yes

Contd....2p.

3) The Management has stated that, they have satisfied with the installations and maintenance of the fire safety equipment working condition in the above Educational building and also declared that no kitchen and A/c are provided in the premises and no additions or alterations have been made in the building affecting Fire Prevention and Fire Safety Measures including means of escape and that all exits and passages are free from any obstruction.

4) It is the responsibility of the Management to ensure the above Fire Safety Measures and maintain them in good working condition in the above Educational Building. The Management is responsible all risks involved incase of Fire Accidents

5) In view of the above and based on the self certification submitted by the Management and also taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country, the No Objection Certificate for Occupancy is issued to the M/s Donbosco Primary School (The Guntupalli Donbosco Society), located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Grama Panchayat, Ibrahimpatnam Mandal, Krishna District subject to the following conditions:

- (i) The Management is responsible for all risks involved in case of Fire Accident.
- (ii) This NOC is given based on the information, documents and drawings provided by the applicant. The applicant confirms that the information provided and the documents and drawings submitted are correct. Any deviation noticed will lead to cancellation of NOC without any notice.
- (iii) The permission accorded does not confer any ownership rights. If it is found that the information furnished is false and fabricated, the permission will be revoked at any stage and the applicant will be liable for criminal prosecution as per IPC.
- (iv) The Management shall ensure the following precautions strictly at all the times:

6) Maintain the following conditions compulsorily for safety point of view.

Sl. No.	As Builder	As occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency.
4	This No objection Certificate for occupancy only for fire safety point of view.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

7) This No Objection Certificate for Occupancy is valid for a period of Five years only (One year Occupancy + Four Years Renewal) from the date of issue of this letter. The owner/ Occupier/Builder/Management concerned of the building shall submit self declaration/ Certification every year in the prescribed format and submit/upload the photographs of the Mock drills conducted in the premises. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.90, Home (Prisons & Fire) Department, dated.13-08-2021 before expiry of this No Objection Certificate.

8) This No Objection Certificate is issued, subject to the outcome of O.As/W.Ps etc., if any, before Courts etc.,

Yours Sincerely,


Director General,

State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the M/s Donbosco Primary School (The Guntupalli Donbosco Society), located at R.S.No.243 & 244, D.No.5-132/2, Guntupalli Grama Panchayat, Ibrahimpatnam Mandal, Krishna District.

Copy to the District Fire Officer, Krishna.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.

